



Test
TS EN ISO/IEC 17025
AB-0386-T

AB-0386-T

2009.33.02/00

09.03.2021



www.testla.com.tr

TESTLA

Elektrik Laboratuvarları Tic. Ltd. Şti.

Kuzuluk Mah. Ankara Cad. No:34

Akyazı / SAKARYA TÜRKİYE

+90 264 437 97 70

laboratuvar@testla.com.tr

TEST REPORT

Client Name/Address	IP ENCLOSURES PTY. LTD. 19-27 Fred Chaplin Circuit, Bells Creek, QLD, 4551, Australia P: 1300 876 722 ABN: 94 168 980 854		
Name and Identity of Test Item	RECESSED DOOR FIELD CABINET		
Order No.	2009.33	Sample Acceptance Date	05.03.2021
Num. Of Pages of The Report	8 + 1 pages of annexes 9 pages in total	Test Date(s)	09.03.2021
Test Standard(s) Rating(s)	IEC 60529: 04.03.1997 Clause: 13, 14.2.6 IP66 <i>Detail(s) is/are given at the page 3</i>		
Test Result(s)	POSITIVE / Details, are given on the following pages which are part of this report.		

Remarks

TESTLA Elektrik Laboratuvarları accredited by TÜRKAK under registration number AB-0386-T for TS EN ISO/TS EN 17025:2017 as test laboratory.

Turkish Accreditation Agency (TURKAK) is a signatory to the European co-operation for Accreditation (EA) Multilateral Agreement (MLA) and to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) for the recognition of test reports.

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Seal

Date

Person in Charge of Test

Approval
Date



09.03.2021

Mehmet ŞUMNU

2021.03.
10
16:01:04
+03'00'

Caner EREN
Laboratory Manager

This report shall not be reproduced other than in full except with the permission of the laboratory. Testing reports without signature is not valid.

Date format: dd.mm.yyyy